

SECTION 5

5.05 OPERATING PRESSURES WITHIN THE DISTRIBUTION SYSTEM:

Pressures within the Distribution System shall be a minimum of 40 pounds per square inch during the maximum hour demand and a maximum of 110 pounds per square inch static pressure in the main. The maximum pressure fluctuation at any location in the Distribution System between maximum hour demand and minimum hour demand shall not exceed 30 pounds per square inch.